

## CERTIFICATE

## of constancy of performance 1922 - CPR - 1974

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fire detection and fire alarm systems. Alarm transmission and fault warning routing equipment. Cellular Communicator: G17F

(with the performance listed, see Annex I to 1922-CPR-1974 that is an inseparable part of this certificate)

placed on the market under the name or trade mark of

**UAB TRIKDIS** 

Draugystes st 17, Kaunas, LT-51229, Lithuania

and produced in the manufacturing plant

**UAB TRIKDIS** 

Draugystes st 17, Kaunas, LT-51229, Lithuania

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

## EN 54-21:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 15.05.2023 and will remain valid until 15.05.2024 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.









Manager:

dipl. eng. Anna Vasileva

Burgas, 15 May 2023

Ref. No. 01-00



## ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 1974/15.05.2023

Performance list, acc. to EN 54-21:2006

| Essential Characteristics   | Performance | Clause |
|---|-------------|--------|
| Performance of transmission   |             |        |
| - General requirements  | Pass        | 4      |
| - Functional requirements   | Pass        | 5      |
| Operational reliability   |             |        |
| - General requirements  | Pass        | 4      |
| - Functional requirements   | Pass        | 5      |
| - Design requirements   | Pass        | 7      |
| - Marking   | Pass        | 8      |
| - Power supply  | Pass        | 9      |
| Durability of operational reliability, temperature resistance       |             |        |
| - Cold (operational)  | Pass        | 10.4   |
| Durability of operational reliability, vibration resistance         |             |        |
| - Impact (operational)  | Pass        | 10.6   |
| - Vibration, sinusoidal (operational)                               | Pass        | 10.7   |
| - Vibration, sinusoidal (endurance)                                 | Pass        | 10.11  |
| Durability of operational reliability, electrical stability         |             |        |
| - Electromagnetic compatibility (EMC), immunity tests (operational) | Pass        | 10.8   |
| - Supply voltage variations   | Pass        | 10.9   |
| Durability of operational reliability, humidity resistance          |             |        |
| - Damp heat, steady state (operational)                             | Pass        | 10.5   |
| - Damp heat, steady state (endurance)                               | Pass        | 10.10  |









Manager:

dipl. eng. Anna Vasileva